

TAMILNADU TRANSMISSION CORPORATION LTD

STATEMENT OF DEVIATION ENERGY CHARGES (PROVISIONAL) for the Intra State Private Generators
April -20

SL.No.	Name of the Generator	EDC	Scheduling Period	Scheduled Energy in Kwhr	Actual Energy injection (Ex bus) in Kwhr	Actual Energy injection Limited to Schedule in Kwhr (Excess injection not allowed)	Deviation Energy in Kwhr (Under injection lesser than interstate sale Schedule)	Normal Deviation charges ie upto 110% of Schedule in Rs.	Additional Deviation Charges in Rs (Payable by the Generator)			Total Deviation Charges (Normal Deviation charges- Additional Deviation charges) in Rs.
									Frequency >= 49.85 Hz & Under Injection more than 10%	Under Injection At Freq <49.85	Over Injection at Frequency >= 50.05 Hz	
1	M/s Sakthi Sugars Ltd, Jothinagar, Sivaganga HTSC 117	Sivaganga	April- 20	0	0	0	0	0	0	0	0	0
2	M/s Sakthi Sugars Ltd, Appakudal,Sakthinagar HTSC 07	Erode	April- 20	0	0	0	0	0	0	0	0	0
3	M/s Sakthi Sugars Ltd, Poondurai HTSC 299	Erode	April- 20	0	0	0	0	0	0	0	0	0
4	M/s Birla Carbon India Private Ltd, Gummidipoondi HTSC 1990	Chennai North	April- 20	0	0	0	0	0	0	0	0	0
5	Tamil Nadu Newsprint & Papers Ltd HTSC 15	Karur	April- 20	74422	249891	72412	-2010	-5604	-3320	0	-8217	-17141
6	Chettinad Cement Corporation Ltd - Ariyalur HTSC -70	Perambalur	April- 20	0	0	0	0	0	0	0	0	0
7	Chettinad Cement Corporation Ltd - Karikkali HTSC -345	Dindigul	April- 20	0	0	0	0	0	0	0	0	0
8	Chettinad Cement Corporation Ltd, Karikkali HTSC 397	Dindigul	April- 20	0	0	0	0	0	0	0	0	0
9	Chettinad Cement Corporation Ltd, Puliur HTSC 101	Karur	April- 20	0	0	0	0	0	0	0	0	0
10	Dalmia Cement (Bharat) Limited, Ariyalur HTSC 74	Perambalur	April- 20	0	0	0	0	0	0	0	0	0

SL.No.	Name of the Generator	EDC	Scheduling Period	Scheduled Energy in Kwhr	Actual Energy injection (Ex bus) in Kwhr	Actual Energy injection Limited to Schedule in Kwhr (Excess injection not allowed)	Deviation Energy in Kwhr (Under injection lesser than interstate sale Schedule)	Normal Deviation charges ie upto 110% of Schedule in Rs.	Additional Deviation Charges in Rs (Payable by the Generator)			Total Deviation Charges (Normal Deviation charges- Additional Deviation charges) in Rs.
									Frequency >= 49.85 Hz & Under Injection more than 10%	Under Injection At Freq <49.85	Over Injection at Frequency >= 50.05 Hz	
11	OPG Power Generation PVT Ltd, Gummidipoondi HTSC -1881	Chennai North	April- 20	0	0	0	0	0	0	0	0	0
12	E.I.D. Parry (India) Ltd Nellikuppam HTSC 100	Cuddalore	April- 20	1573641	1654551	1530676	-42965	-136073	-107313	-6661	-27173	-277220
13	E.I.D. Parry (India) Ltd Pudukkottai HTSC 116	Pudhukkottai	April- 20	0	0	0	0	0	0	0	0	0
14	E.I.D. Parry (India) Ltd Pugalur HTSC 76	Karur	April- 20	0	0	0	0	0	0	0	0	0
15	M/s Tamil Nadu Newsprint & Papers Ltd Unit II - HTSC 264	Trichy Metro	April- 20	74258	173448	74226	-32	-98	0	0	-2300	-2398
16	Chemplast Sanmar Limited HTSC 23	Mettur	April- 20	0	0	0	0	0	0	0	0	0
17	Tamil Nadu Coke & Power Pvt Ltd HTSC 1960	Chennai North	April- 20	0	0	0	0	0	0	0	0	0
Total				1722321			-45007	-141775	-110633	-6661	-37690	-296759

Deviation amount in (- ve) indicates amount Receivable from Generators by TANGEDCO/TANTRANSCO