

TAMILNADU TRANSMISSION CORPORATION LTD

STATEMENT OF DEVIATION ENERGY CHARGES (PROVISIONAL) for the Intra State Private Generators
July -20

SL.No.	Name of the Generator	EDC	Scheduling Period	Scheduled Energy in Kwhr	Actual Energy injection (Ex bus) in Kwhr	Actual Energy injection Limited to Schedule in Kwhr (Excess injection not allowed)	Deviation Energy in Kwhr (Under injection lesser than interstate sale Schedule)	Normal Deviation charges ie upto 110% of Schedule in Rs.	Additional Deviation Charges in Rs (Payable by the Generator)			Total Deviation Charges (Normal Deviation charges- Additional Deviation charges) in Rs.
									Frequency >= 49.85 Hz & Under Injection more than 10%	Under Injection At Freq <49.85	Over Injection at Frequency >= 50.05 Hz	
1	M/s Sakthi Sugars Ltd, Jothinagar, Sivaganga HTSC 117	Sivaganga	July- 20	0	0	0	0	0	0	0	0	0
2	M/s Sakthi Sugars Ltd, Appakudal,Sakthinagar HTSC 07	Erode	July- 20	4195387	4434042	4052030	-143357	-418028	-123986	-9219	-20022	-571255
3	M/s Sakthi Sugars Ltd, Poondurai HTSC 299	Erode	July- 20	0	0	0	0	0	0	0	0	0
4	M/s Birla Carbon India Private Ltd, Gummidipoondi HTSC 1990	Chennai North	July- 20	2540570	15008021	2540570	0	0	0	0	0	0
5	Tamil Nadu Newsprint & Papers Ltd HTSC 15	Karur	July- 20	496144	837783	475002	-21142	-60741	-45226	-1137	-15793	-122898
6	Chettinad Cement Corporation Ltd - Ariyalur HTSC -70	Perambalur	July- 20	3101	3000	2825	-275	-992	-257	0	0	-1249
7	Chettinad Cement Corporation Ltd - Karikkali HTSC -345	Dindigul	July- 20	9927	10034	9699	-228	-794	0	0	0	-794
8	Chettinad Cement Corporation Ltd, Karikkali HTSC 397	Dindigul	July- 20	0	0	0	0	0	0	0	0	0
9	Chettinad Cement Corporation Ltd, Puliur HTSC 101	Karur	July- 20	4636	4757	4586	-51	-94	-1	0	0	-95
10	Dalmia Cement (Bharat) Limited, Ariyalur HTSC 74	Perambalur	July- 20	710405	727740	699053	-11352	-52392	-28316	-8688	-5368	-94764

SL.No.	Name of the Generator	EDC	Scheduling Period	Scheduled Energy in Kwhr	Actual Energy injection (Ex bus) in Kwhr	Actual Energy injection Limited to Schedule in Kwhr (Excess injection not allowed)	Deviation Energy in Kwhr (Under injection lesser than interstate sale Schedule)	Normal Deviation charges ie upto 110% of Schedule in Rs.	Additional Deviation Charges in Rs (Payable by the Generator)			Total Deviation Charges (Normal Deviation charges- Additional Deviation charges) in Rs.
									Frequency >= 49.85 Hz & Under Injection more than 10%	Under Injection At Freq <49.85	Over Injection at Frequency >= 50.05 Hz	
11	E.I.D. Parry (India) Ltd Nellikuppam HTSC 100	Cuddalore	July- 20	213962	213524	206378	-7584	-20778	-8367	0	-269	-29414
12	E.I.D. Parry (India) Ltd Pudukkottai HTSC 116	Pudhukkottai	July- 20	0	0	0	0	0	0	0	0	0
13	E.I.D. Parry (India) Ltd Pugalur HTSC 76	Karur	July- 20	1789548	5762830	1779094	-10454	-31856	-26440	0	-17274	-75570
14	M/s Tamil Nadu Newsprint & Papers Ltd Unit II - HTSC 264	Trichy Metro	July- 20	1232399	1357728	1226278	-6120	-20784	-6948	-46	-25961	-53738
15	Chemplast Sanmar Limited HTSC 23	Mettur	July- 20	0	0	0	0	0	0	0	0	0
16	Tamil Nadu Coke & Power Pvt Ltd HTSC 1960	Chennai North	July- 20	0	0	0	0	0	0	0	0	0
Total				11196080			-200563	-606459	-239542	-19090	-84687	-949777

Deviation amount in (- ve) indicates amount Receivable from Generators by TANGEDCO/TANTRANSCO