TAMIL NADU TRANSMISSION CORPORATION LIMITED
TAMIL NADU STATE LOAD DESPATCH CENTRE
Import of Tamil Nadu Power Transfer Capability for April 2025

Issue Date : 12.04.2024 Issue Time : 18:00 Hrs Revision No. 0

Months	Time Period in IST (Hrs)	Total Transfer Capability	Reliability Margin	Available Transfer Capability	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Apr-25	0:00 - 24:00	13500	350	13150	8098	5052	0	
Limiting Constraints:	1. N-1 contigency of 400/230 kV 2 x 315 MVA ICT's at Thiruvalam 400 kV SS 2. Tripping of 400/230 kV 1x500 MVA ICT will lead to overloading of 2 x 315 MVA ICTs at Arasur PG SS 3. N-1 contigency of 400/230 kV 2 x 250 MVA ICT's and 2 x 500 MVA ICTs at NLC TS2 and NNTPS							