TAMIL NADU TRANSMISSION CORPORATION LIMITED
TAMIL NADU STATE LOAD DESPATCH CENTRE
Import of Tamil Nadu Power Transfer Capability for August 2024

Issue Date : 11.10.2023 Issue Time : 18:00 Hrs Revision No. 0

Months	Time Period in IST (Hrs)	Total Transfer Capability	Reliability Margin	Available Transfer Capability	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Aug-24	0:00 - 24:00	13200	350	12850	8155	4695	0	
Limiting Constraints:	1. N-1 contigency of 400/230 kV ICT's at NLC TS2 and NNTPS 2. N-1 contigency of 400/230 kV ICT's at Alundur 400 kV SS 3. N-1 contigency of 400/230 kV ICT's at Thiruvalam 400 kV SS 4. N-1 contigency of 400/230 kV ICT's at Vellalaviduthi 400 kV SS							