TAMIL NADU TRANSMISSION CORPORATION LIMITED
TAMIL NADU STATE LOAD DESPATCH CENTRE
Import of Tamil Nadu Power Transfer Capability for February 2025

Issue Date : 14.02.2024 Issue Time : 18:00 Hrs Revision No. 0

Months	Time Period in IST (Hrs)	Total Transfer Capability	Reliability Margin	Available Transfer Capability	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Feb-25	0:00 - 24:00	13500	350	13150	7939	5211	0	
Limiting Constraints:	1. N-1 contigency of 400/230 kV ICT's at NLC TS2 and NNTPS 2. N-1 contigency of 400/230 kV ICT's at Arasur 400 kV SS 3. N-1 contigency of 400/230 kV ICT's at Thiruvalam 400 kV SS							