# TAMIL NADU TRANSMISSION CORPORATION LIMITED
## TAMIL NADU STATE LOAD DESPATCH CENTRE
### Import of Tamil Nadu Power Transfer Capability for February 2025

Issue Date : 13.01.2025 Issue Time : 18:00 Hrs Revision No. 1

| Months | Time Period in IST (Hrs) | Total Transfer Capability | Reliability Margin | Available Transfer Capability | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---|---|---|---|---|---|---|---|
| Feb-25 | 0:00 - 24:00 | 14050 | 350 | 13700 | 9177 | 4523 | 0 | - |
| **Limiting Constraints:** | 1. Tripping of 400kV NCTPS-Manali S/C will cause overloading of 400kV Alamathy-Manali S/C<br>2.N-1 contigency of 400/230 kV 2 x 250 MVA ICT's at NLC TS2<br>3. N-1 contigency of 400/230 kV 2 x 500 MVA ICTs at NNTPS<br>4.Tripping of 400/230 kV 1x500 MVA ICT will lead to overloading of 2 x 315 MVA ICTs at Kalivanthapattu PG SS<br>5. N-1 violation of 400/230 kV 2 x 315 MVA ICt's at Salem TN SS | | | | | | | |