

Issue Date :		11.12.2023		Issue Time :		18:00 Hrs		Revision No. 2	
Months	Time Period in IST (Hrs)	Total Transfer Capability	Reliability Margin	Available Transfer Capability	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
Jan-24	0:00 - 24:00	13300	350	12950	7810	5140	2	Commissioning of 230 kV NTKudi-Karaikudi line 2	
Limiting Constraints:	1. N-1 contingency of 400/230 kV ICT's at NLC TS2 and NNTPS 2. N-1 contingency of 400/230 kV ICT's at Alundur 400 kV SS 3. N-1 contingency of 400/230 kV ICT's at Thiruvalem 400 kV SS 4. N-1 contingency of 400/230 kV ICT's at Vellalaviduthi 400 kV SS								