TAMIL NADU TRANSMISSION CORPORATION LIMITED
TAMIL NADU STATE LOAD DESPATCH CENTRE
Import of Tamil Nadu Power Transfer Capability for January 2026

Issue Date : 13.01.2025 Issue Time : 12:00 Hrs Revision No. 0

Months	Time Period in IST (Hrs)	Total Transfer Capability	Reliability Margin	Available Transfer Capability	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Jan-26	0:00 - 24:00	14050	350	13700	9177	4523	-	-
Limiting Constraints:	1. Tripping of 400kV NCTPS-Manali S/C will cause overloading of 400kV Alamathy-Manali S/C 2.N-1 contigency of 400/230 kV 2 x 250 MVA ICT's at NLC TS2 3. N-1 contigency of 400/230 kV 2 x 500 MVA ICTs at NNTPS 4.Tripping of 400/230 kV 1x500 MVA ICT will lead to overloading of 2 x 315 MVA ICTs at Kalivanthapattu PG SS 5. N-1 violation of 400/230 kV 2 x 315 MVA ICt's at Salem TN SS							