TAMIL NADU TRANSMISSION CORPORATION LIMITED
TAMIL NADU STATE LOAD DESPATCH CENTRE
Import of Tamil Nadu Power Transfer Capability for November 2025

Issue Date : 13.10.2025 Issue Time : 18:00 Hrs Revision No. 1

Months	Time Period in IST (Hrs)	Total Transfer Capability	Reliability Margin	Available Transfer Capability	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Nov-25	00:00 - 24:00	14600	420	14180	9177	5003	0	
Limiting Constraints:	1. N-1 contigency of 400/230 kV 2 x 250 MVA ICT's at NLC TS2 2. N-1 contigency of 400/230 kV 2 x 500 MVA ICTs at NNTPS 3. Tripping of 400kV NCTPS-Manali S/C will cause overloading of 400kV Alamathy-Manali S/C (SPS implemented) 4. Tripping of 400/230 kV 1x500 MVA ICT will lead to overloading of 2 x 315 MVA ICTs at Kalivanthapattu PG SS 5. Tripping of 400/230 kV 1x500 MVA ICT will lead to overloading of 2 x 315 MVA ICTs at Pugalur PG SS"□							